

**IMPORTANT LEGAL MATERIALS**

FOR OFFICIAL USE ONLY

**NATIONWIDE UPONOR SETTLEMENT  
LOW FLOW FAILURE TEST FORM**

Owner Name: \_\_\_\_\_

Property Address: \_\_\_\_\_

Date of Test: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

Fixture Location	Time to Fill (HOT)	Time to Fill (COLD)

I declare under penalty of perjury that the above information is true. I agree to an inspection of my property and examination of my records to verify this information.

Owner Name: \_\_\_\_\_

Owner Signature: \_\_\_\_\_

Date: \_\_\_\_ / \_\_\_\_ / \_\_\_\_

**Instructions for conducting the test for Low Flow Failure:**

Tools required: a container of at least one gallon capacity and a watch with a second hand.

- Ensure that all fixtures other than the one being tested are OFF.
- Place the container under the faucet being tested. Turn the hot water tap on full and measure the time required to completely fill the container. Empty the container and repeat the test using the cold water tap on full.
- Record both of the times on this form.
- Repeat the test for any fixtures where low flow failure is suspected.

Claims must be submitted within six months from the date of the test. **Test results will be independently verified.** E-mail completed forms to [Warrantyclaims.us@uponor.com](mailto:Warrantyclaims.us@uponor.com), or submit by mail to:

Uponor, Inc.  
5925 148th St W  
Apple Valley, MN 55124

Questions? Call 1-800-876-6671 toll-free